

Environmental Water Services



Operations &
Maintenance

Water & Wastewater
Services

City Of Wykoff

Monthly Council Report

Reporting for the Month of January 2025

- 1.) Completed DMR no limit exceedances.
- 2.) Completed rounds, checks and process control.
- 3.) Conducted MLSS checks.
- 4.) Checked biological activity under microscope.
- 5.) Met with John Friel regarding current wastewater troubleshooting.
- 6.) Assisted with overseeing water main break repair.
- 7.) 0 alarm calls wet weather events no flooding.
- 8.) Performed 2 Locates.
- 9.) Met with Streets Committee
- 10.) Found hanging heater had quit in well house installed temporary heat source
- 11.) Monitored and fueled heat Source throughout the weekend and Monday.
- 12.) Ordered parts and repaired well house heater.
- 13.) Climbed the water tower to reset radio for meters at City Hall.
- 14.) Sent fluoride and chlorine sample
- 15.) Attended Hazardous mitigation planning meeting.
- 16.) Responded to sewer backup complaint and inspected city Assets.